

Location	Iron (mg/l) SMCL – 1.3 mg/l	Manganese (mg/l) SMCL – 0.05 mg/l
Raw Water	0.12	0.18
Entry Point (Finished)	<0.02	0.03
300,000 Gallon Tank	<0.02	0.04
1 MG Tank	0.05	0.03
North Schuylkill HS	<0.02	0.06
Butler Twp Muni	<0.02	0.05
Ashland Sewer	0.03	0.07
Rite Aid	<0.02	<0.02
Donut Shop	0.14	0.06
Turkey Hill	0.02	1.98 actually magnesium result
NMay's	0.05	<0.02 manganese result
Borough Hall	0.05	0.04